

CE TEST CERTIFICATE

FOR PERFORMANCE CHARACTERISTICS OF CONSTRUCTION PRODUCTS FOR THE CE MARKING

BOD-10-01-04-02

Product: „Laminate floor covering D1416 WG, 8 mm with Antistatic-Overlay U8505”

Manufacturer: Kronospan Schweiz AG
Willisauerstrasse 37
6122 Menznau
Switzerland

Order: Classification of the electrostatic behaviour according to
EN 14041:2008

Test method: Test of the body voltage according to EN 1815:1997

Test report: No. 279432 from 2009-12-21

Test result: The measured body voltage at 23 °C / 25 % humidity were ≤ 2 kV.
The „Laminate floor covering D1416 WG, 8 mm with Antistatic-Overlay U8505”
fulfils the criterions for the classification as an
"Antistatic Floor Covering"
in accordance with the European Standard EN 14041:2008

Dresden, 4 January 2010



Head of laboratory





Engineer in charge